



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

August 5, 2010

In reply refer to:
Adai: 248636

Mr. A.C. Entingh
Head, Environmental Compliance Department
AC/S Environmental Security
U.S. Marine Corps Base
P.O. Box 555008
Camp Pendleton, CA 92055-5008

Dear Mr. Entingh:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR SEWAGE TREATMENT
PLANT 9 (STP #9)**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the June 2009-June 2010 monthly and the January-December 2009 annual monitoring report submitted by the United States Marine Corps (USMC) in accordance with the Monitoring and Reporting Program of Order No. 98-04.

The San Diego Water Board has the following comments regarding the monitoring reports submitted:

1. The USMC reported that a spill of 211,000 gallons of secondary treated wastewater occurred from equalization ponds at Sewage Treatment Plant #9 from June 6 to July 9, 2009, which was due to leakage from the floating covers of the ponds. This spill was in violation of Prohibition A.1 of Order No. 98-04. The USMC, however, reported that corrections had been made to stop the leakage from the ponds.
2. The next monitoring report to be submitted is the July 2010 monthly monitoring report due by August 30, 2010.

California Environmental Protection Agency


Mr. Entingh

- 2 -

August 5, 2010

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Mr. Fisayo Osibodu at (858) 637-5594 or via email at oosibodu@waterboards.ca.gov.

Sincerely,



Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 375351
Violation ID: 878304

California Environmental Protection Agency